P.B. No.4, UDYOGAMANDAL P.O., KOCHI – 683501, KERALA

CORRIGENDUM DETAILS

Date: 12/12/2019

Tender Ref No : TCC/PROJ/CIVIL/08/2019
Tender ID : 2019 TCCL 326389 1

For item No. 10 in BOQ, the contractor can quote unit rate for using either Ready Mix Concrete (RMC) or for RCC using departmental issue cement at site.

In case of RMC he shall specify the same in Cover I of his offer. Before commencement of work, the contractor should submit design mix details for the M30 grade Ready Mix Concrete to be used for approval of Engineer in charge. The contractor should also arrange a trial mix in the presence of Engineer in Charge to check the parameters of design mix and its test result in an approved lab by the Engineer in Charge.

The make of cement shall be either any of the following.

- 1. Malabar Cement
- 2. Ambuja Cement
- 3. ACC Cement
- 4. Ultratech Cement
- 5. JK Cements

In Case of RMC, Cost of required cement (350kg/m³ for M30 grade) at Rs. 380/50kg bag shall be paid to the contractor.

The following documents shall also be summited by the contractor.

- 1. Test report of 7 and 28 days concrete strength.
- 2. Design mix calculation of M30 grade concrete as per IS code

Sd/-

Dy. General Manager (Projects)

EPBX No : 0484-2545011-16, 6005011-14, Fax : 0484- 2546564, E-mail : mail@tcckerala.com/ Visit : www.tcckerala.com